



**KW AUFZUGSTECHNIK GmbH**  
Zimmersmühlenweg 69  
D-61440 Oberursel - GERMANY  
TEL. ++49 (0) 6171-9895-0 FAX ++49 (0) 6171-9895-19



### Emergency Power Device NSG-16

The Emergency Devices Series NSG-16 devices are robust, with interesting features. In the standard package is a 12V battery with 1.2 AH, externally fasten. The device may be a current of 1.0 A at 12V DC. In addition, a voltage output of +8 V DC. The Emergency Devices also has an alarm relay on the board, which is a floating exchange contact, for example, for the emergency phone and facilities. The Alarm output is 0 to 3 seconds programmable, so that an Abuse suppression can be realized.

# Connection-plan and Terminals of the NSG-16-12

Manual NSG16-12 KW Aufzugstechnik GmbH

Date 13.05.2000

Terminal	Function	Terminal	Function
L1	Phase L 230 V AC	12	Akku-Supply +12V
N	Null-Neutral N		
PE	Earth PE		
1	Alert contact com	15	Akku-Supply -12V
2	Alert contact no	16	Akku voltage +13V DC
3	Alert contact nc	17	Voltage +12V DC
4	Alert Pushbottom +13V DC	18	Voltage + 8V DC
5	Alert Pushbottom Input	19	GND 0V DC
6	Alert Horn +13V DC	20	Input Switch Off for Night
7	Alert Horn 0V DC	21	Input Switch Off for Night
8	Level Indicator /Akku +13VDC		
9	Level Indicator /Akku 0VDC		
10	Emergency Light +13V DC		
11	Emergency Light 0V DC		

